TKT65C CENTRAL BATTERY SYSTEMS



Central battery system in TKT65xxCX series, as all our Tapsa Control central battery systems, takes care of the testing automatically.

Suitable for medium sized and large buildings.

Technical data:

input voltage 230 VAC
output voltage under normal conditions 230 VAC
output voltage in battery mode 216 VDC

We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: March 29, 2024 | Source: teknoware.com/en/emergency-lighting/central-battery-systems/central-battery-systems-product-families/tkt65c-central-battery-systems

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com

battery voltage of 216 V is generated by 18 pieces of 12 V batteries connected in series
8, 16 or 24 output circuits
max 16 luminaires per circuit
ADDRESSABLE 230 V CENTRAL BATTERY SYSTEMS

Product Code	Nominal Supply Voltage	Number of Output Circuits	Max Load of Circuits (VA)
TKT6508C	1~ N/PE 220-240 VAC, 50 Hz	8 x 250 VA / W	
TKT6516C	1~ N/PE 220-240 VAC, 50 Hz	16 x 250 VA / W	
TKT6524C	1~ N/PE 220-240 VAC, 50 Hz	24 x 250 VA / W	
TKT6508CP	1~ N/PE 220-240 VAC, 50 Hz	8 x 250 VA / W	
TKT6516CP	1~ N/PE 220-240 VAC, 50 Hz	16 x 250 VA / W	
TKT6524CP	1~ N/PE 220-240 VAC, 50 Hz	24 x 250 VA / W	

We reserve the rights to make modifications without notice.
Copyright © 2024 Teknoware. All rights reserved.
Date: March 29, 2024 | Source: teknoware.com/en/emergency-lighting/central-battery-systems/central-battery-systems-product-families/tkt65c-central-battery-systems

Teknoware Oy | P.O. Box 19, 15101 Lahti | Ilmarisentie 8, 15200 Lahti Finland
Tel +358 3 883 020 | VAT-number FI01494751 | teknoware.com | emexit@teknoware.com